

**Addendum #3
for
Hampton Inn
Brannon Crossings, Nicholasville, KY
Project No. 8038.01**

December 11, 2008

NOTICE TO BIDDERS:

- A. This Addendum shall be considered part of the Contract Documents for the above-mentioned project, dated August 1, 2008, as though it had been issued at the same time and shall be incorporated integrally therewith. Where the provisions of the following supplementary data differ from those of the original Contract Documents this Addendum shall govern and take precedence.
- B. Bidders are hereby notified that they shall make any necessary adjustments in their estimate on account of this Addendum. It will be construed that each Bidder's Proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

1. Due to availability of wood species in the area, the specified structural lumber may be revised as follows:

First Floor:

Exterior Walls: Southern Pine Dense Select Structural, Fc 2150, E 1.9, 2x6 framing at 12" o.c.

Interior Bearing walls: Southern Pine Grade stud*, Fc 825, E 1.4, 2x6 framing at 12" o.c. with two rows blocking at third points.

Second and Third Floors:

Exterior Walls: Southern Pine Grade Stud*, Fc 825, E 1.4. 2x6 framing at 16" o.c.

Interior Bearing Walls: Southern Pine Grade Stud, Fc 825, E 1.4, 2x6 framing at 16" o.c. with two rows blocking at third points.

Fourth Floor:

Exterior Walls: Southern Pine Grade Stud*, Fc 825, E 1.4. 2x6 framing at 16" o.c.

Interior Bearing Walls: Southern Pine Grade Stud, Fc 825, E 1.4, 2x6 framing at 16" o.c. with one row blocking at midpoint.

* SPF grade may be used in lieu of southern pine provided that E1.4 is met. However, exterior walls on first floor must have E1.9 properties.

CLEVELAND OFFICE
3723 pearl road
cleveland, ohio 44109
216.749.7800 t
216.749.1300 f

LORAIN OFFICE
201 ½ west 5th street
lorain, ohio, 44052
440.246.3100 t
440.246.5017 f

End of Addendum No. 3